

To,

THE DIRECTOR OF BOILERS, WEST BENGAL

New Secretariat Building (8th floor)
1, K.S. Roy Road, KOLKATA - 700001

Sir,

Name of the Owner: 7 MILLION

Locality: 1/1 Kalitala lane , P.O : Baidyabati, Hooghly, Pin : 712222

Boiler Maker's No: PTPL-08/205, Boiler Type: **Package**, Date of Inspection: **03-01-2020**

Sub: Hydraulic test of boiler along with steam and feed water pipe lines.

Ref: i) Owners Letter No.NIL

ii) Office Report No WB/R/2019/1628 Dt:25-12-2019

With reference to the above and my subsequent visit to above premises, this is to report that the Boiler alongwith Steam and Feed Water pipe lines were offered for witnessing of hydraulic test. The hydraulic tests were carried out as follows and found to be in order. The observations are as below :-

Sl. No.	Equipments	Working Pressure (Kg/cm ²)	Hyd. Test Pressure Pressure(Kg/cm ²)	Remarks
1	Boiler	10.54	15.81	satisfactory
2	Steam Pipe Line	10.54	15.81	satisfactory
3	Feed Water Line	12.0	18.0	satisfactory

Owners may now be advised to submit Form III/A of steam and feed water pipe lines with necessary documents for scrutiny and subsequent approval of the same and further necessary action.

Provisional order of steaming is kept withheld pending the following:

i. Approval of III/A of steam and feed water pipe lines with necessary documents.

Your's faithfully

Sri Subhashis Das, Assistant Director of Boilers, W.B.

No. WB/R/2020/0015.date 06-01-2020

Copy forwarded for information and necessary action to:-

i) **7 MILLION**, 1/1 Kalitala lane , P.O. : Baidyabati, Hooghly, PIN : 712222

ii) Sri Subhashis Das, Assistant Director of Boilers, W.B.

Joint Director of Boilers, W.B.